

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 21)**

Water Level of the accumulated water (at 7:00 on January 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,935 mm (74 mm increase since 7:00 on January 20)	O.P.+ 2,710 mm (33 mm decrease since 7:00 on January 20)	—
	Water level of Turbine Building	O.P.+ 2,457 mm (1 mm increase since 7:00 on January 20)	O.P.+ 2,957 mm (63 mm increase since 7:00 on January 20)	O.P.+ 2,700 mm (51 mm decrease since 7:00 on January 20)	O.P.+ 2,725 mm (23 mm decrease since 7:00 on January 20)
	Water level of Reactor Building	O.P.+ 3,830 mm (19 mm decrease since 7:00 on January 20)	O.P.+ 3,055 mm (39 mm increase since 7:00 on January 20)	O.P.+ 2,781 mm (56 mm decrease since 7:00 on January 20)	O.P.+ 2,753 mm (8 mm decrease since 7:00 on January 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,240 mm (Increase from initial level:5,457 mm, 3 mm increase since 7:00 on January 20) O.P.+ 3,034 mm (Increase from initial level:3,760 mm, 117 mm increase since 7:00 on January 20) O.P.+ 4,415 mm (Water level from floor:619 mm, 7 mm increase since 7:00 on January 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:12 on January 19 to 9:29 on January 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 16:00 on December 17 to 9:14 on January 21)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:32 on January 15   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.