

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 22)**

Water Level of the accumulated water (at 7:00 on January 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,010 mm (75 mm increase since 7:00 on January 21)	O.P.+ 2,719 mm (9 mm increase since 7:00 on January 21)	—
	Water level of Turbine Building	O.P.+ 2,457 mm (No change since 7:00 on January 21)	O.P.+ 3,020 mm (63 mm increase since 7:00 on January 21)	O.P.+ 2,754 mm (54 mm increase since 7:00 on January 21)	O.P.+ 2,711 mm (14 mm decrease since 7:00 on January 21)
	Water level of Reactor Building	O.P.+ 3,828 mm (2 mm decrease since 7:00 on January 21)	O.P.+ 3,114 mm (59 mm increase since 7:00 on January 21)	O.P.+ 2,825 mm (44 mm increase since 7:00 on January 21)	O.P.+ 2,742 mm (11 mm decrease since 7:00 on January 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,245 mm (Increase from initial level:5,462 mm, 5 mm increase since 7:00 on January 21) O.P.+ 2,465 mm (Increase from initial level:3,191 mm, 569 mm decrease since 7:00 on January 21) O.P.+ 4,421 mm (Water level from floor:625 mm, 6 mm increase since 7:00 on January 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:32 on January 15   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.