

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 23)**

Water Level of the accumulated water (at 7:00 on January 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,085 mm (75 mm increase since 7:00 on January 22)	O.P.+ 2,738 mm (19 mm increase since 7:00 on January 22)	—
	Water level of Turbine Building	O.P.+ 2,460 mm (3 mm increase since 7:00 on January 22)	O.P.+ 3,079 mm (59 mm increase since 7:00 on January 22)	O.P.+ 2,779 mm (25 mm increase since 7:00 on January 22)	O.P.+ 2,721 mm (10 mm increase since 7:00 on January 22)
	Water level of Reactor Building	O.P.+ 3,835 mm (7 mm increase since 7:00 on January 22)	O.P.+ 3,166 mm (52 mm increase since 7:00 on January 22)	O.P.+ 2,854 mm (29 mm increase since 7:00 on January 22)	O.P.+ 2,738 mm (4 mm decrease since 7:00 on January 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,250 mm (Increase from initial level:5,467 mm, 5 mm increase since 7:00 on January 22) O.P.+ 1,884 mm (Increase from initial level:2,610 mm, 581 mm decrease since 7:00 on January 22) O.P.+ 4,425 mm (Water level from floor:629 mm, 4 mm increase since 7:00 on January 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:25 on January 23 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 7:25 AM on January 23, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.