

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 24)**

Water Level of the accumulated water (at 7:00 on January 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,145 mm (60 mm increase since 7:00 on January 23)	O.P.+ 2,757 mm (19 mm increase since 7:00 on January 23)	—
	Water level of Turbine Building	O.P.+ 2,459 mm (1 mm decrease since 7:00 on January 23)	O.P.+ 3,129 mm (50 mm increase since 7:00 on January 23)	O.P.+ 2,796 mm (17 mm increase since 7:00 on January 23)	O.P.+ 2,736 mm (15 mm increase since 7:00 on January 23)
	Water level of Reactor Building	O.P.+ 3,850 mm (15 mm increase since 7:00 on January 23)	O.P.+ 3,214 mm (48 mm increase since 7:00 on January 23)	O.P.+ 2,875 mm (21 mm increase since 7:00 on January 23)	O.P.+ 2,745 mm (7 mm increase since 7:00 on January 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,255 mm (Increase from initial level:5,472 mm, 5 mm increase since 7:00 on January 23) O.P.+ 1,634 mm (Increase from initial level:2,360 mm, 250 mm decrease since 7:00 on January 23) O.P.+ 4,430 mm (Water level from floor:634 mm, 5 mm increase since 7:00 on January 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:45 on January 23   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 7:25 AM on January 23, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 4:16 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 4:45 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.