

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 27)**

Water Level of the accumulated water (at 7:00 on January 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,197 mm (70 mm decrease since 7:00 on January 26)	O.P.+ 2,706 mm (4 mm increase since 7:00 on January 26)	—
	Water level of Turbine Building	O.P.+ 2,460 mm (1 mm decrease since 7:00 on January 26)	O.P.+ 3,172 mm (58 mm decrease since 7:00 on January 26)	O.P.+ 2,741 mm (45 mm increase since 7:00 on January 26)	O.P.+ 2,701 mm (16 mm decrease since 7:00 on January 26)
	Water level of Reactor Building	O.P.+ 3,926 mm (20 mm increase since 7:00 on January 26)	O.P.+ 3,298 mm (28 mm decrease since 7:00 on January 26)	O.P.+ 2,815 mm (32 mm increase since 7:00 on January 26)	O.P.+ 2,736 mm (11 mm decrease since 7:00 on January 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,265 mm (Increase from initial level:5,482 mm, 3 mm increase since 7:00 on January 26) O.P.+ 1,720 mm (Increase from initial level:2,446 mm, 98 mm increase since 7:00 on January 26) O.P.+ 4,446 mm (Water level from floor:650 mm, 5 mm increase since 7:00 on January 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:33 on January 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:45 on January 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.