

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 28)**

Water Level of the accumulated water (at 7:00 on January 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,132 mm (65 mm decrease since 7:00 on January 27)	O.P.+ 2,721 mm (15 mm increase since 7:00 on January 27)	—
	Water level of Turbine Building	O.P.+ 2,462 mm (2 mm increase since 7:00 on January 27)	O.P.+ 3,118 mm (54 mm decrease since 7:00 on January 27)	O.P.+ 2,761 mm (20 mm increase since 7:00 on January 27)	O.P.+ 2,709 mm (8 mm increase since 7:00 on January 27)
	Water level of Reactor Building	O.P.+ 3,923 mm (3 mm decrease since 7:00 on January 27)	O.P.+ 3,251 mm (47 mm decrease since 7:00 on January 27)	O.P.+ 2,841 mm (26 mm increase since 7:00 on January 27)	O.P.+ 2,732 mm (4 mm decrease since 7:00 on January 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,267 mm (Increase from initial level:5,484 mm, 2 mm increase since 7:00 on January 27) O.P.+ 1,818 mm (Increase from initial level:2,544 mm, 98 mm increase since 7:00 on January 27) O.P.+ 4,451 mm (Water level from floor:655 mm, 5 mm increase since 7:00 on January 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:33 on January 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:45 on January 23   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.