

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 29)**

Water Level of the accumulated water (at 7:00 on January 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,069 mm (63 mm decrease since 7:00 on January 28)	O.P.+ 2,739 mm (18 mm increase since 7:00 on January 28)	—
	Water level of Turbine Building	O.P.+ 2,463 mm (1 mm increase since 7:00 on January 28)	O.P.+ 3,063 mm (55 mm decrease since 7:00 on January 28)	O.P.+ 2,776 mm (15 mm increase since 7:00 on January 28)	O.P.+ 2,720 mm (11 mm increase since 7:00 on January 28)
	Water level of Reactor Building	O.P.+ 3,917 mm (6 mm decrease since 7:00 on January 28)	O.P.+ 3,203 mm (48 mm decrease since 7:00 on January 28)	O.P.+ 2,856 mm (15 mm increase since 7:00 on January 28)	O.P.+ 2,735 mm (3 mm increase since 7:00 on January 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,272 mm (Increase from initial level:5,489 mm, 5 mm increase since 7:00 on January 28) O.P.+ 1,950 mm (Increase from initial level:2,676 mm, 132 mm increase since 7:00 on January 28) O.P.+ 4,457 mm (Water level from floor:661 mm, 6 mm increase since 7:00 on January 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:33 on January 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:45 on January 23   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.