

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 3)**

Water Level of the accumulated water (at 7:00 on February 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,801 mm (51 mm decrease since 7:00 on February 2)	O.P.+ 2,795 mm (11 mm increase since 7:00 on February 2)	—
	Water level of Turbine Building	O.P.+ 2,465 mm (2 mm increase since 7:00 on February 2)	O.P.+ 2,840 mm (44 mm decrease since 7:00 on February 2)	O.P.+ 2,838 mm (12 mm increase since 7:00 on February 2)	O.P.+ 2,776 mm (12 mm increase since 7:00 on February 2)
	Water level of Reactor Building	O.P.+ 3,797 mm (24 mm decrease since 7:00 on February 2)	O.P.+ 2,989 mm (37 mm decrease since 7:00 on February 2)	O.P.+ 2,930 mm (21 mm increase since 7:00 on February 2)	O.P.+ 2,776 mm (10 mm increase since 7:00 on February 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,361 mm (Increase from initial level:5,578 mm, 3 mm increase since 7:00 on February 2) O.P.+ 1,989 mm (Increase from initial level:2,715 mm, 52 mm decrease since 7:00 on February 2) O.P.+ 4,266 mm (Water level from floor:470 mm, 5 mm increase since 7:00 on February 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:33 on January 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:30 on January 30   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.