

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 4)**

Water Level of the accumulated water (at 7:00 on February 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,875 mm (74 mm increase since 7:00 on February 3)	O.P.+ 2,765 mm (30 mm decrease since 7:00 on February 3)	—
	Water level of Turbine Building	O.P.+ 2,466 mm (1 mm increase since 7:00 on February 3)	O.P.+ 2,904 mm (64 mm increase since 7:00 on February 3)	O.P.+ 2,774 mm (64 mm decrease since 7:00 on February 3)	O.P.+ 2,769 mm (7 mm decrease since 7:00 on February 3)
	Water level of Reactor Building	O.P.+ 3,781 mm (16 mm decrease since 7:00 on February 3)	O.P.+ 3,005 mm (16 mm increase since 7:00 on February 3)	O.P.+ 2,870 mm (60 mm decrease since 7:00 on February 3)	O.P.+ 2,780 mm (4 mm increase since 7:00 on February 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,365 mm (Increase from initial level:5,582 mm, 4 mm increase since 7:00 on February 3) O.P.+ 1,943 mm (Increase from initial level:2,669 mm, 46 mm decrease since 7:00 on February 3) O.P.+ 4,271 mm (Water level from floor:475 mm, 5 mm increase since 7:00 on February 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 9:33 on January 26 to 9:27 on February 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:30 on January 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.