

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 5)**

Water Level of the accumulated water (at 7:00 on February 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,963 mm (88 mm increase since 7:00 on February 4)	O.P.+ 2,730 mm (35 mm decrease since 7:00 on February 4)	—
	Water level of Turbine Building	O.P.+ 2,468 mm (2 mm increase since 7:00 on February 4)	O.P.+ 2,978 mm (74 mm increase since 7:00 on February 4)	O.P.+ 2,721 mm (53 mm decrease since 7:00 on February 4)	O.P.+ 2,746 mm (23 mm decrease since 7:00 on February 4)
	Water level of Reactor Building	O.P.+ 3,771 mm (10 mm decrease since 7:00 on February 4)	O.P.+ 3,068 mm (63 mm increase since 7:00 on February 4)	O.P.+ 2,812 mm (58 mm decrease since 7:00 on February 4)	O.P.+ 2,776 mm (4 mm decrease since 7:00 on February 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,371 mm (Increase from initial level:5,588 mm, 6 mm increase since 7:00 on February 4) O.P.+ 1,904 mm (Increase from initial level:2,630 mm, 39 mm decrease since 7:00 on February 4) O.P.+ 4,275 mm (Water level from floor:479 mm, 4 mm increase since 7:00 on February 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:30 on January 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.