

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 6)**

Water Level of the accumulated water (at 7:00 on February 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,036 mm (73 mm increase since 7:00 on February 5)	O.P.+ 2,695 mm (35 mm decrease since 7:00 on February 5)	—
	Water level of Turbine Building	O.P.+ 2,467 mm (1 mm decrease since 7:00 on February 5)	O.P.+ 3,040 mm (62 mm increase since 7:00 on February 5)	O.P.+ 2,675 mm (46 mm decrease since 7:00 on February 5)	O.P.+ 2,718 mm (28 mm decrease since 7:00 on February 5)
	Water level of Reactor Building	O.P.+ 3,774 mm (3 mm increase since 7:00 on February 5)	O.P.+ 3,127 mm (59 mm increase since 7:00 on February 5)	O.P.+ 2,759 mm (53 mm decrease since 7:00 on February 5)	O.P.+ 2,763 mm (13 mm decrease since 7:00 on February 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,376 mm (Increase from initial level:5,593 mm, 5 mm increase since 7:00 on February 5) O.P.+ 1,868 mm (Increase from initial level:2,594 mm, 36 mm decrease since 7:00 on February 5) O.P.+ 4,278 mm (Water level from floor:482 mm, 3 mm increase since 7:00 on February 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:30 on January 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.