

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 7)**

Water Level of the accumulated water (at 7:00 on February 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,100 mm (64 mm increase since 7:00 on February 6)	O.P.+ 2,660 mm (35 mm decrease since 7:00 on February 6)	—
	Water level of Turbine Building	O.P.+ 2,468 mm (1 mm increase since 7:00 on February 6)	O.P.+ 3,088 mm (48 mm increase since 7:00 on February 6)	O.P.+ 2,635 mm (40 mm decrease since 7:00 on February 6)	O.P.+ 2,691 mm (27 mm decrease since 7:00 on February 6)
	Water level of Reactor Building	O.P.+ 3,788 mm (14 mm increase since 7:00 on February 6)	O.P.+ 3,171 mm (44 mm increase since 7:00 on February 6)	O.P.+ 2,716 mm (43 mm decrease since 7:00 on February 6)	O.P.+ 2,744 mm (19 mm decrease since 7:00 on February 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,378 mm (Increase from initial level:5,595 mm, 2 mm increase since 7:00 on February 6) O.P.+ 1,946 mm (Increase from initial level:2,672 mm, 78 mm increase since 7:00 on February 6) O.P.+ 4,283 mm (Water level from floor:487 mm, 5 mm increase since 7:00 on February 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:47 on February 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:36 AM on February 6, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:23 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 12:47 PM on the same day (*1). *1 In our previous report (as of 9:00 AM on February 7, 2014), we announced "2nd Cesium Adsorption Apparatus (Sarry): Since 14:30 on January 30 In operation." Since the apparatus had been suspended from 9:36 AM to 12:23 PM on February 6 for a filter cleaning, we corrected it as "Since 12:47 on February 6 In operation" on February 8, 2014. We sincerely apologize for the mistake.				

※ For quick publication of the data of water level, values are provided as reference values.