

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 10)**

Water Level of the accumulated water (at 7:00 on February 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,272 mm (58 mm increase since 7:00 on February 9)	O.P.+ 2,566 mm (33 mm decrease since 7:00 on February 9)	—
	Water level of Turbine Building	O.P.+ 2,471 mm (1 mm increase since 7:00 on February 9)	O.P.+ 3,233 mm (49 mm increase since 7:00 on February 9)	O.P.+ 2,540 mm (29 mm decrease since 7:00 on February 9)	O.P.+ 2,604 mm (28 mm decrease since 7:00 on February 9)
	Water level of Reactor Building	O.P.+ 3,840 mm (48 mm increase since 7:00 on February 9)	O.P.+ 3,313 mm (47 mm increase since 7:00 on February 9)	O.P.+ 2,611 mm (34 mm decrease since 7:00 on February 9)	O.P.+ 2,668 mm (26 mm decrease since 7:00 on February 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,386 mm (Increase from initial level:5,603 mm, 2 mm increase since 7:00 on February 9) O.P.+ 1,873 mm (Increase from initial level:2,599 mm, 15 mm decrease since 7:00 on February 9) O.P.+ 4,297 mm (Water level from floor:501 mm, 3 mm increase since 7:00 on February 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:47 on February 6   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.