

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 12)**

Water Level of the accumulated water (at 7:00 on February 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,143 mm (69 mm decrease since 7:00 on February 11)	O.P.+ 2,590 mm (20 mm increase since 7:00 on February 11)	—
	Water level of Turbine Building	O.P.+ 2,473 mm (1 mm increase since 7:00 on February 11)	O.P.+ 3,125 mm (58 mm decrease since 7:00 on February 11)	O.P.+ 2,631 mm (34 mm increase since 7:00 on February 11)	O.P.+ 2,589 mm (5 mm increase since 7:00 on February 11)
	Water level of Reactor Building	O.P.+ 3,865 mm (5 mm decrease since 7:00 on February 11)	O.P.+ 3,240 mm (53 mm decrease since 7:00 on February 11)	O.P.+ 2,703 mm (39 mm increase since 7:00 on February 11)	O.P.+ 2,639 mm (9 mm decrease since 7:00 on February 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,391 mm (Increase from initial level:5,608 mm, 2 mm increase since 7:00 on February 11) O.P.+ 1,865 mm (Increase from initial level:2,591 mm, 1 mm decrease since 7:00 on February 11) O.P.+ 4,305 mm (Water level from floor:509 mm, 3 mm increase since 7:00 on February 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:00 on February 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:47 on February 6   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.