

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 13)**

Water Level of the accumulated water (at 7:00 on February 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,076 mm (67 mm decrease since 7:00 on February 12)	O.P.+ 2,608 mm (18 mm increase since 7:00 on February 12)	—
	Water level of Turbine Building	O.P.+ 2,472 mm (1 mm decrease since 7:00 on February 12)	O.P.+ 3,074 mm (51 mm decrease since 7:00 on February 12)	O.P.+ 2,654 mm (23 mm increase since 7:00 on February 12)	O.P.+ 2,603 mm (14 mm increase since 7:00 on February 12)
	Water level of Reactor Building	O.P.+ 3,845 mm (20 mm decrease since 7:00 on February 12)	O.P.+ 3,195 mm (45 mm decrease since 7:00 on February 12)	O.P.+ 2,726 mm (23 mm increase since 7:00 on February 12)	O.P.+ 2,643 mm (4 mm increase since 7:00 on February 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,397 mm (Increase from initial level:5,614 mm, 6 mm increase since 7:00 on February 12) O.P.+ 1,873 mm (Increase from initial level:2,599 mm, 8 mm increase since 7:00 on February 12) O.P.+ 4,308 mm (Water level from floor:512 mm, 3 mm increase since 7:00 on February 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:00 on February 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:47 on February 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.