

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 14)**

Water Level of the accumulated water (at 7:00 on February 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,039 mm (37 mm decrease since 7:00 on February 13)	O.P.+ 2,625 mm (17 mm increase since 7:00 on February 13)	—
	Water level of Turbine Building	O.P.+ 2,474 mm (2 mm increase since 7:00 on February 13)	O.P.+ 3,043 mm (31 mm decrease since 7:00 on February 13)	O.P.+ 2,664 mm (10 mm increase since 7:00 on February 13)	O.P.+ 2,616 mm (13 mm increase since 7:00 on February 13)
	Water level of Reactor Building	O.P.+ 3,814 mm (31 mm decrease since 7:00 on February 13)	O.P.+ 3,158 mm (37 mm decrease since 7:00 on February 13)	O.P.+ 2,743 mm (23 mm increase since 7:00 on February 13)	O.P.+ 2,654 mm (11 mm increase since 7:00 on February 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,402 mm (Increase from initial level:5,619 mm, 5 mm increase since 7:00 on February 13) O.P.+ 2,061 mm (Increase from initial level:2,787 mm, 188 mm increase since 7:00 on February 13) O.P.+ 4,311 mm (Water level from floor:515 mm, 3 mm increase since 7:00 on February 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:00 on February 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:05 on February 13 to 15:00 on February 13)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:23 on February 13   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:15 AM on February 13, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 1:46 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 2:23 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.