

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 17)**

Water Level of the accumulated water (at 7:00 on February 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,960 mm (27 mm decrease since 7:00 on February 16)	O.P.+ 2,717 mm (15 mm increase since 7:00 on February 16)	—
	Water level of Turbine Building	O.P.+ 2,576 mm (45 mm increase since 7:00 on February 16)	O.P.+ 2,976 mm (21 mm decrease since 7:00 on February 16)	O.P.+ 2,758 mm (12 mm increase since 7:00 on February 16)	O.P.+ 2,690 mm (26 mm increase since 7:00 on February 16)
	Water level of Reactor Building	O.P.+ 4,143 mm (34 mm increase since 7:00 on February 16)	O.P.+ 3,105 mm (29 mm decrease since 7:00 on February 16)	O.P.+ 2,840 mm (11 mm increase since 7:00 on February 16)	O.P.+ 2,710 mm (17 mm increase since 7:00 on February 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,414 mm (Increase from initial level:5,631 mm, 5 mm increase since 7:00 on February 16) O.P.+ 2,011 mm (Increase from initial level:2,737 mm, 14 mm decrease since 7:00 on February 16) O.P.+ 4,331 mm (Water level from floor:535 mm, 5 mm increase since 7:00 on February 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:00 on February 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:23 on February 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.