

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 18)**

|  |   |  |  |  |  |
|--|---|--|--|--|--|
| Water Level of the accumulated water<br>(at 7:00 on February 18) |   | Unit 1   | Unit 2   | Unit 3   | Unit 4   |
|  | Water level of Vertical Shaft   | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)  | O.P.+ 2,934 mm<br>(26 mm decrease since 7:00 on February 17)   | O.P.+ 2,733 mm<br>(16 mm increase since 7:00 on February 17)   | —  |
|  | Water level of Turbine Building   | O.P.+ 2,612 mm<br>(36 mm increase since 7:00 on February 17)   | O.P.+ 2,952 mm<br>(24 mm decrease since 7:00 on February 17)   | O.P.+ 2,770 mm<br>(12 mm increase since 7:00 on February 17)   | O.P.+ 2,711 mm<br>(21 mm increase since 7:00 on February 17) |
|  | Water level of Reactor Building   | O.P.+ 4,112 mm<br>(31 mm decrease since 7:00 on February 17)   | O.P.+ 3,085 mm<br>(20 mm decrease since 7:00 on February 17)   | O.P.+ 2,853 mm<br>(13 mm increase since 7:00 on February 17)   | O.P.+ 2,726 mm<br>(16 mm increase since 7:00 on February 17) |
|  | Water level of each building in the Centralized Radiation Waste Treatment Facility  | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building  | O.P.+ 4,417 mm (Increase from initial level:5,634 mm, 3 mm increase since 7:00 on February 17)<br>O.P.+ 1,989 mm (Increase from initial level:2,715 mm, 22 mm decrease since 7:00 on February 17)<br>O.P.+ 4,338 mm (Water level from floor:542 mm, 7 mm increase since 7:00 on February 17) |  |  |
| Situation of transfer of the accumulated water                   |   | Unit 1   | Unit 2   | Unit 3   | Unit 4   |
|  |   | —  | Basement of Unit 2 Turbine Building<br>→Basement of Unit 3 Turbine Building<br>Currently being transferred<br>(Since 10:00 on February 10)   | Basement of Unit 3 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred<br>(Since 14:37 on January 24) | —  |
|  |   | Unit 5 and 6   |  |  |  |
|  |   | Basement of Unit 6 Turbine Building<br>→Temporary Tank   | Transfer Completed   | (From 10:00 on February 17 to 15:00 on February 17)  |  |
| Operation condition of water treatment facility                  |   | Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 8:23 on February 18   Suspended<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |  |  |  |
| Notes  | * At 8:23 AM on February 18, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. |  |  |  |  |

※ For quick publication of the data of water level, values are provided as reference values.