

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 20)**

Water Level of the accumulated water (at 7:00 on February 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,125 mm (95 mm increase since 7:00 on February 19)	O.P.+ 2,681 mm (23 mm decrease since 7:00 on February 19)	—
	Water level of Turbine Building	O.P.+ 2,672 mm (27 mm increase since 7:00 on February 19)	O.P.+ 3,112 mm (79 mm increase since 7:00 on February 19)	O.P.+ 2,682 mm (29 mm decrease since 7:00 on February 19)	O.P.+ 2,695 mm (14 mm decrease since 7:00 on February 19)
	Water level of Reactor Building	O.P.+ 4,037 mm (32 mm decrease since 7:00 on February 19)	O.P.+ 3,201 mm (70 mm increase since 7:00 on February 19)	O.P.+ 2,764 mm (32 mm decrease since 7:00 on February 19)	O.P.+ 2,734 mm (2 mm decrease since 7:00 on February 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,429 mm (Increase from initial level:5,646 mm, 6 mm increase since 7:00 on February 19) O.P.+ 2,052 mm (Increase from initial level:2,778 mm, 50 mm decrease since 7:00 on February 19) O.P.+ 4,347 mm (Water level from floor:551 mm, 4 mm increase since 7:00 on February 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on February 19 to 15:00 on February 19)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:12 on February 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.