

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 21)**

Water Level of the accumulated water (at 7:00 on February 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,207 mm (82 mm increase since 7:00 on February 20)	O.P.+ 2,646 mm (35 mm decrease since 7:00 on February 20)	—
	Water level of Turbine Building	O.P.+ 2,697 mm (25 mm increase since 7:00 on February 20)	O.P.+ 3,182 mm (70 mm increase since 7:00 on February 20)	O.P.+ 2,633 mm (49 mm decrease since 7:00 on February 20)	O.P.+ 2,676 mm (19 mm decrease since 7:00 on February 20)
	Water level of Reactor Building	O.P.+ 4,016 mm (21 mm decrease since 7:00 on February 20)	O.P.+ 3,271 mm (70 mm increase since 7:00 on February 20)	O.P.+ 2,723 mm (41 mm decrease since 7:00 on February 20)	O.P.+ 2,727 mm (7 mm decrease since 7:00 on February 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,434 mm (Increase from initial level:5,651 mm, 5 mm increase since 7:00 on February 20) O.P.+ 2,005 mm (Increase from initial level:2,731 mm, 47 mm decrease since 7:00 on February 20) O.P.+ 4,353 mm (Water level from floor:557 mm, 4 mm increase since 7:00 on February 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on February 20 to 15:00 on February 20)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:12 on February 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.