

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 24)**

Water Level of the accumulated water (at 7:00 on February 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,166 mm (66 mm decrease since 7:00 on February 23)	O.P.+ 2,645 mm (26 mm increase since 7:00 on February 23)	—
	Water level of Turbine Building	O.P.+ 2,754 mm (16 mm increase since 7:00 on February 23)	O.P.+ 3,146 mm (54 mm decrease since 7:00 on February 23)	O.P.+ 2,689 mm (38 mm increase since 7:00 on February 23)	O.P.+ 2,643 mm (1 mm decrease since 7:00 on February 23)
	Water level of Reactor Building	O.P.+ 3,936 mm (4 mm decrease since 7:00 on February 23)	O.P.+ 3,272 mm (47 mm decrease since 7:00 on February 23)	O.P.+ 2,771 mm (47 mm increase since 7:00 on February 23)	O.P.+ 2,698 mm (9 mm decrease since 7:00 on February 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,321 mm (Increase from initial level:5,538 mm, 3 mm increase since 7:00 on February 23) O.P.+ 1,879 mm (Increase from initial level:2,605 mm, 40 mm decrease since 7:00 on February 23) O.P.+ 4,369 mm (Water level from floor:573 mm, 6 mm increase since 7:00 on February 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:37 on February 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:12 on February 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.