

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 27)**

Water Level of the accumulated water (at 7:00 on February 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,009 mm (48 mm decrease since 7:00 on February 26)	O.P.+ 2,707 mm (22 mm increase since 7:00 on February 26)	—
	Water level of Turbine Building	O.P.+ 2,781 mm (6 mm increase since 7:00 on February 26)	O.P.+ 3,015 mm (40 mm decrease since 7:00 on February 26)	O.P.+ 2,750 mm (22 mm increase since 7:00 on February 26)	O.P.+ 2,690 mm (17 mm increase since 7:00 on February 26)
	Water level of Reactor Building	O.P.+ 3,870 mm (29 mm decrease since 7:00 on February 26)	O.P.+ 3,145 mm (39 mm decrease since 7:00 on February 26)	O.P.+ 2,848 mm (28 mm increase since 7:00 on February 26)	O.P.+ 2,710 mm (8 mm increase since 7:00 on February 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,337 mm (Increase from initial level:5,554 mm, 5 mm increase since 7:00 on February 26) O.P.+ 1,998 mm (Increase from initial level:2,724 mm, 89 mm decrease since 7:00 on February 26) O.P.+ 4,384 mm (Water level from floor:588 mm, 6 mm increase since 7:00 on February 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:37 on February 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:17 on February 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.