

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 28)**

Water Level of the accumulated water (at 7:00 on February 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,960 mm (49 mm decrease since 7:00 on February 27)	O.P.+ 2,732 mm (25 mm increase since 7:00 on February 27)	—
	Water level of Turbine Building	O.P.+ 2,786 mm (5 mm increase since 7:00 on February 27)	O.P.+ 2,975 mm (40 mm decrease since 7:00 on February 27)	O.P.+ 2,777 mm (27 mm increase since 7:00 on February 27)	O.P.+ 2,709 mm (19 mm increase since 7:00 on February 27)
	Water level of Reactor Building	O.P.+ 3,848 mm (22 mm decrease since 7:00 on February 27)	O.P.+ 3,120 mm (25 mm decrease since 7:00 on February 27)	O.P.+ 2,873 mm (25 mm increase since 7:00 on February 27)	O.P.+ 2,720 mm (10 mm increase since 7:00 on February 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,345 mm (Increase from initial level:5,562 mm, 8 mm increase since 7:00 on February 27) O.P.+ 1,913 mm (Increase from initial level:2,639 mm, 85 mm decrease since 7:00 on February 27) O.P.+ 4,389 mm (Water level from floor:593 mm, 5 mm increase since 7:00 on February 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:37 on February 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on February 27 to 15:00 on February 27)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:17 on February 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.