

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 3)**

Water Level of the accumulated water (at 7:00 on March 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,952 mm (85 mm increase since 7:00 on March 2)	O.P.+ 2,726 mm (27 mm decrease since 7:00 on March 2)	—
	Water level of Turbine Building	O.P.+ 2,570 mm (225 mm decrease since 7:00 on March 2)	O.P.+ 2,968 mm (73 mm increase since 7:00 on March 2)	O.P.+ 2,737 mm (62 mm decrease since 7:00 on March 2)	O.P.+ 2,737 mm (2 mm decrease since 7:00 on March 2)
	Water level of Reactor Building	O.P.+ 3,816 mm (15 mm increase since 7:00 on March 2)	O.P.+ 3,072 mm (33 mm increase since 7:00 on March 2)	O.P.+ 2,842 mm (60 mm decrease since 7:00 on March 2)	O.P.+ 2,752 mm (8 mm increase since 7:00 on March 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,356 mm (Increase from initial level:5,573 mm, 4 mm increase since 7:00 on March 2) O.P.+ 1,679 mm (Increase from initial level:2,405 mm, 73 mm decrease since 7:00 on March 2) O.P.+ 4,400 mm (Water level from floor:604 mm, 5 mm increase since 7:00 on March 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 10:08 on March 2 to 16:58 on March 2)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:37 on February 22 to 9:38 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:17 on February 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.