

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 4)**

Water Level of the accumulated water (at 7:00 on March 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,041 mm (89 mm increase since 7:00 on March 3)	O.P.+ 2,698 mm (28 mm decrease since 7:00 on March 3)	—
	Water level of Turbine Building	O.P.+ 2,574 mm (4 mm increase since 7:00 on March 3)	O.P.+ 3,042 mm (74 mm increase since 7:00 on March 3)	O.P.+ 2,700 mm (37 mm decrease since 7:00 on March 3)	O.P.+ 2,721 mm (16 mm decrease since 7:00 on March 3)
	Water level of Reactor Building	O.P.+ 3,840 mm (24 mm increase since 7:00 on March 3)	O.P.+ 3,134 mm (62 mm increase since 7:00 on March 3)	O.P.+ 2,799 mm (43 mm decrease since 7:00 on March 3)	O.P.+ 2,752 mm (No change since 7:00 on March 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,359 mm (Increase from initial level:5,576 mm, 3 mm increase since 7:00 on March 3) O.P.+ 1,606 mm (Increase from initial level:2,332 mm, 73 mm decrease since 7:00 on March 3) O.P.+ 4,404 mm (Water level from floor:608 mm, 4 mm increase since 7:00 on March 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 9:30 on March 3 to 15:30 on March 3)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:17 on February 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.