

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 6)**

Water Level of the accumulated water (at 7:00 on March 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,212 mm (85 mm increase since 7:00 on March 5)	O.P.+ 2,642 mm (29 mm decrease since 7:00 on March 5)	—
	Water level of Turbine Building	O.P.+ 2,584 mm (7 mm increase since 7:00 on March 5)	O.P.+ 3,185 mm (71 mm increase since 7:00 on March 5)	O.P.+ 2,622 mm (34 mm decrease since 7:00 on March 5)	O.P.+ 2,684 mm (19 mm decrease since 7:00 on March 5)
	Water level of Reactor Building	O.P.+ 3,909 mm (51 mm increase since 7:00 on March 5)	O.P.+ 3,292 mm (81 mm increase since 7:00 on March 5)	O.P.+ 2,731 mm (31 mm decrease since 7:00 on March 5)	O.P.+ 2,739 mm (6 mm decrease since 7:00 on March 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,501 mm (Increase from initial level:5,718 mm, 5 mm increase since 7:00 on March 5) O.P.+ 1,559 mm (Increase from initial level:2,285 mm, 79 mm decrease since 7:00 on March 5) O.P.+ 4,412 mm (Water level from floor:616 mm, 4 mm increase since 7:00 on March 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 9:30 on March 5 to 15:30 on March 5)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:43 on March 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Water gauge used to measure water level data at the Process Main Building was changed from this measurement.				

※ For quick publication of the data of water level, values are provided as reference values.