

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 7)**

Water Level of the accumulated water (at 7:00 on March 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,285 mm (73 mm increase since 7:00 on March 6)	O.P.+ 2,608 mm (34 mm decrease since 7:00 on March 6)	—
	Water level of Turbine Building	O.P.+ 2,590 mm (6 mm increase since 7:00 on March 6)	O.P.+ 3,243 mm (58 mm increase since 7:00 on March 6)	O.P.+ 2,580 mm (42 mm decrease since 7:00 on March 6)	O.P.+ 2,659 mm (25 mm decrease since 7:00 on March 6)
	Water level of Reactor Building	O.P.+ 3,946 mm (37 mm increase since 7:00 on March 6)	O.P.+ 3,339 mm (47 mm increase since 7:00 on March 6)	O.P.+ 2,681 mm (50 mm decrease since 7:00 on March 6)	O.P.+ 2,725 mm (14 mm decrease since 7:00 on March 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,505 mm (Increase from initial level:5,722 mm, 4 mm increase since 7:00 on March 6) O.P.+ 1,484 mm (Increase from initial level:2,210 mm, 75 mm decrease since 7:00 on March 6) O.P.+ 4,417 mm (Water level from floor:621 mm, 5 mm increase since 7:00 on March 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on March 6 to 15:00 on March 6)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:43 on March 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.