

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 10)**

Water Level of the accumulated water (at 7:00 on March 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,232 mm (64 mm decrease since 7:00 on March 9)	O.P.+ 2,604 mm (24 mm increase since 7:00 on March 9)	—
	Water level of Turbine Building	O.P.+ 2,609 mm (7 mm increase since 7:00 on March 9)	O.P.+ 3,198 mm (53 mm decrease since 7:00 on March 9)	O.P.+ 2,638 mm (44 mm increase since 7:00 on March 9)	O.P.+ 2,610 mm (2 mm decrease since 7:00 on March 9)
	Water level of Reactor Building	O.P.+ 3,987 mm (4 mm decrease since 7:00 on March 9)	O.P.+ 3,343 mm (42 mm decrease since 7:00 on March 9)	O.P.+ 2,731 mm (48 mm increase since 7:00 on March 9)	O.P.+ 2,684 mm (10 mm decrease since 7:00 on March 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,518 mm (Increase from initial level:5,735 mm, 5 mm increase since 7:00 on March 9) O.P.+ 1,282 mm (Increase from initial level:2,008 mm, 64 mm decrease since 7:00 on March 9) O.P.+ 4,432 mm (Water level from floor:636 mm, 6 mm increase since 7:00 on March 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on March 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:37 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:43 on March 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.