

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 12)**

Water Level of the accumulated water (at 7:00 on March 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,109 mm (60 mm decrease since 7:00 on March 11)	O.P.+ 2,690 mm (31 mm increase since 7:00 on March 11)	—
	Water level of Turbine Building	O.P.+ 2,613 mm (2 mm increase since 7:00 on March 11)	O.P.+ 3,094 mm (51 mm decrease since 7:00 on March 11)	O.P.+ 2,735 mm (34 mm increase since 7:00 on March 11)	O.P.+ 2,654 mm (25 mm increase since 7:00 on March 11)
	Water level of Reactor Building	O.P.+ 3,939 mm (27 mm decrease since 7:00 on March 11)	O.P.+ 3,243 mm (44 mm decrease since 7:00 on March 11)	O.P.+ 2,830 mm (33 mm increase since 7:00 on March 11)	O.P.+ 2,689 mm (7 mm increase since 7:00 on March 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,464 mm (Increase from initial level:5,681 mm, 72 mm decrease since 7:00 on March 11) O.P.+ 1,254 mm (Increase from initial level:1,980 mm, 13 mm increase since 7:00 on March 11) O.P.+ 4,440 mm (Water level from floor:644 mm, 4 mm increase since 7:00 on March 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on March 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:51 on March 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:40 on March 10 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 10:54 on March 10 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.