

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 14)**

Water Level of the accumulated water (at 7:00 on March 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,997 mm (50 mm decrease since 7:00 on March 13)	O.P.+ 2,751 mm (31 mm increase since 7:00 on March 13)	—
	Water level of Turbine Building	O.P.+ 2,621 mm (5 mm increase since 7:00 on March 13)	O.P.+ 3,005 mm (41 mm decrease since 7:00 on March 13)	O.P.+ 2,803 mm (38 mm increase since 7:00 on March 13)	O.P.+ 2,706 mm (26 mm increase since 7:00 on March 13)
	Water level of Reactor Building	O.P.+ 3,930 mm (18 mm increase since 7:00 on March 13)	O.P.+ 3,172 mm (29 mm decrease since 7:00 on March 13)	O.P.+ 2,907 mm (38 mm increase since 7:00 on March 13)	O.P.+ 2,715 mm (15 mm increase since 7:00 on March 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,998 mm (Increase from initial level:5,215 mm, 269 mm decrease since 7:00 on March 13) O.P.+ 2,083 mm (Increase from initial level:2,809 mm, 483 mm increase since 7:00 on March 13) O.P.+ 4,450 mm (Water level from floor:654 mm, 5 mm increase since 7:00 on March 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on March 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:40 on March 10 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 10:54 on March 10 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.