

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 17)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on March 17)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,839 mm (53 mm decrease since 7:00 on March 16)	O.P.+ 2,812 mm (6 mm increase since 7:00 on March 16)	—
	Water level of Turbine Building	O.P.+ 2,638 mm (6 mm increase since 7:00 on March 16)	O.P.+ 2,872 mm (45 mm decrease since 7:00 on March 16)	O.P.+ 2,860 mm (3 mm increase since 7:00 on March 16)	O.P.+ 2,789 mm (23 mm increase since 7:00 on March 16)
	Water level of Reactor Building	O.P.+ 3,854 mm (34 mm decrease since 7:00 on March 16)	O.P.+ 3,014 mm (45 mm decrease since 7:00 on March 16)	O.P.+ 2,969 mm (2 mm increase since 7:00 on March 16)	O.P.+ 2,777 mm (22 mm increase since 7:00 on March 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,997 mm (Increase from initial level:5,214 mm, 4 mm increase since 7:00 on March 16) O.P.+ 1,863 mm (Increase from initial level:2,589 mm, 91 mm decrease since 7:00 on March 16) O.P.+ 4,461 mm (Water level from floor:665 mm, 4 mm increase since 7:00 on March 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on March 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6 —			
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:05 on March 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes					

※ For quick publication of the data of water level, values are provided as reference values.