

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 19)**

Water Level of the accumulated water (at 7:00 on March 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,742 mm (46 mm decrease since 7:00 on March 18)	O.P.+ 2,834 mm (13 mm increase since 7:00 on March 18)	—
	Water level of Turbine Building	O.P.+ 2,646 mm (5 mm increase since 7:00 on March 18)	O.P.+ 2,789 mm (41 mm decrease since 7:00 on March 18)	O.P.+ 2,894 mm (22 mm increase since 7:00 on March 18)	O.P.+ 2,823 mm (15 mm increase since 7:00 on March 18)
	Water level of Reactor Building	O.P.+ 3,750 mm (63 mm decrease since 7:00 on March 18)	O.P.+ 2,943 mm (33 mm decrease since 7:00 on March 18)	O.P.+ 2,990 mm (11 mm increase since 7:00 on March 18)	O.P.+ 2,816 mm (19 mm increase since 7:00 on March 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,088 mm (Increase from initial level:5,305 mm, 4 mm increase since 7:00 on March 18) O.P.+ 1,732 mm (Increase from initial level:2,458 mm, 61 mm decrease since 7:00 on March 18) O.P.+ 4,225 mm (Water level from floor:429 mm, 5 mm increase since 7:00 on March 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on March 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:05 on March 14   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.