

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 20)**

Water Level of the accumulated water (at 7:00 on March 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,697 mm (45 mm decrease since 7:00 on March 19)	O.P.+ 2,846 mm (12 mm increase since 7:00 on March 19)	—
	Water level of Turbine Building	O.P.+ 2,651 mm (5 mm increase since 7:00 on March 19)	O.P.+ 2,751 mm (38 mm decrease since 7:00 on March 19)	O.P.+ 2,902 mm (8 mm increase since 7:00 on March 19)	O.P.+ 2,837 mm (14 mm increase since 7:00 on March 19)
	Water level of Reactor Building	O.P.+ 3,658 mm (92 mm decrease since 7:00 on March 19)	O.P.+ 2,904 mm (39 mm decrease since 7:00 on March 19)	O.P.+ 3,004 mm (14 mm increase since 7:00 on March 19)	O.P.+ 2,830 mm (14 mm increase since 7:00 on March 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,092 mm (Increase from initial level:5,309 mm, 4 mm increase since 7:00 on March 19) O.P.+ 1,668 mm (Increase from initial level:2,394 mm, 64 mm decrease since 7:00 on March 19) O.P.+ 4,229 mm (Water level from floor:433 mm, 4 mm increase since 7:00 on March 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on March 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:05 on March 14   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.