

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 25)**

Water Level of the accumulated water (at 7:00 on March 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,139 mm (71 mm increase since 7:00 on March 24)	O.P.+ 2,701 mm (34 mm decrease since 7:00 on March 24)	—
	Water level of Turbine Building	O.P.+ 2,741 mm (19 mm increase since 7:00 on March 24)	O.P.+ 3,118 mm (56 mm increase since 7:00 on March 24)	O.P.+ 2,675 mm (40 mm decrease since 7:00 on March 24)	O.P.+ 2,749 mm (25 mm decrease since 7:00 on March 24)
	Water level of Reactor Building	O.P.+ 3,893 mm (6 mm increase since 7:00 on March 24)	O.P.+ 3,221 mm (60 mm increase since 7:00 on March 24)	O.P.+ 2,767 mm (41 mm decrease since 7:00 on March 24)	O.P.+ 2,809 mm (11 mm decrease since 7:00 on March 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,209 mm (Increase from initial level:5,426 mm, 7 mm increase since 7:00 on March 22) O.P.+ 1,982 mm (Increase from initial level:2,708 mm, 56 mm increase since 7:00 on March 22) O.P.+ 4,340 mm (Water level from floor:544 mm, 14 mm increase since 7:00 on March 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:38 on March 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.