

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 26)**

Water Level of the accumulated water (at 7:00 on March 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,224 mm (85 mm increase since 7:00 on March 25)	O.P.+ 2,667 mm (34 mm decrease since 7:00 on March 25)	—
	Water level of Turbine Building	O.P.+ 2,761 mm (20 mm increase since 7:00 on March 25)	O.P.+ 3,190 mm (72 mm increase since 7:00 on March 25)	O.P.+ 2,638 mm (37 mm decrease since 7:00 on March 25)	O.P.+ 2,722 mm (27 mm decrease since 7:00 on March 25)
	Water level of Reactor Building	O.P.+ 3,908 mm (15 mm increase since 7:00 on March 25)	O.P.+ 3,294 mm (73 mm increase since 7:00 on March 25)	O.P.+ 2,727 mm (40 mm decrease since 7:00 on March 25)	O.P.+ 2,795 mm (14 mm decrease since 7:00 on March 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,212 mm (Increase from initial level:5,429 mm, 10 mm increase since 7:00 on March 25) O.P.+ 2,010 mm (Increase from initial level:2,736 mm, 84 mm increase since 7:00 on March 25) O.P.+ 4,357 mm (Water level from floor:561 mm, 17 mm increase since 7:00 on March 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:16 on March 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:16 AM on March 26, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.