Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 27)

		Unit 1	Unit 2	Unit 3	Unit 4	
Water Level of the accumulated water (at 7:00 on March 27)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,297 mm (73 mm increase since 7:00 on March 26)	O.P.+ 2,625 mm (42 mm decrease since 7:00 on March 26)	_	
	Water level of Turbine Building	O.P.+ 2,777 mm (16 mm increase since 7:00 on March 26)	O.P.+ 3,254 mm (64 mm increase since 7:00 on March 26)	O.P.+ 2,598 mm (40 mm decrease since 7:00 on March 26)	O.P.+ 2,695 mm (27 mm decrease since 7:00 on March 26)	
	Water level of Reactor Building	O.P.+ 3,929 mm (21 mm increase since 7:00 on March 26)	O.P.+ 3,357 mm (63 mm increase since 7:00 on March 26)	O.P.+ 2,685 mm (42 mm decrease since 7:00 on March 26)	O.P.+ 2,780 mm (15 mm decrease since 7:00 on March 26)	
	Water level	Process Main Building	O.P.+ 4,215 mm (Increase from initial level:5,432 mm, 3 mm increase since 7:00 on March 26)			
	of each building in the Centralized Radiation Waste	High Temperature Incinerator Building	O.P.+ 2,193 mm (Increase from initial level:2,919 mm, 183 mm increase since 7:00 on March 26)			
	Treatment Facility	On-site Bunker Building	O.P.+ 4,376 mm (Water level from floor:580 mm, 19 mm increase since 7:00 on March 26)			
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4	
		_	_	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	_	
		Unit 5 and 6				
			_			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:17 on March 27 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes	restarted after the filte	ch 26, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 2:00 PM on the same day, the apparatus was ter cleaning, and the steady flow rate was achieved at 2:24 PM on the same day. At 8:17 AM on March 27, we temporarily stopped the apparatus for a a interlock of a water gauge.				
	·			nuick publication of the data of water level.	values are provided as reference values	