

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 28)**

Water Level of the accumulated water (at 7:00 on March 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,237 mm (60 mm decrease since 7:00 on March 27)	O.P.+ 2,636 mm (11 mm increase since 7:00 on March 27)	—
	Water level of Turbine Building	O.P.+ 2,792 mm (15 mm increase since 7:00 on March 27)	O.P.+ 3,202 mm (52 mm decrease since 7:00 on March 27)	O.P.+ 2,661 mm (63 mm increase since 7:00 on March 27)	O.P.+ 2,675 mm (20 mm decrease since 7:00 on March 27)
	Water level of Reactor Building	O.P.+ 3,959 mm (30 mm increase since 7:00 on March 27)	O.P.+ 3,341 mm (16 mm decrease since 7:00 on March 27)	O.P.+ 2,740 mm (55 mm increase since 7:00 on March 27)	O.P.+ 2,763 mm (17 mm decrease since 7:00 on March 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,215 mm (Increase from initial level:5,432 mm, No change since 7:00 on March 27) O.P.+ 2,320 mm (Increase from initial level:3,046 mm, 127 mm increase since 7:00 on March 27) O.P.+ 4,393 mm (Water level from floor:597 mm, 17 mm increase since 7:00 on March 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:49 on March 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:11 on March 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:17 AM on March 27, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a modification work of a interlock of a water gauge. At 12:57 PM on the same day, the apparatus was restarted after the work, and the steady flow rate was achieved at 1:11 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.