

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 31)**

Water Level of the accumulated water (at 7:00 on March 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,051 mm (52 mm decrease since 7:00 on March 30)	O.P.+ 2,722 mm (36 mm increase since 7:00 on March 30)	—
	Water level of Turbine Building	O.P.+ 2,838 mm (14 mm increase since 7:00 on March 30)	O.P.+ 3,050 mm (41 mm decrease since 7:00 on March 30)	O.P.+ 2,766 mm (34 mm increase since 7:00 on March 30)	O.P.+ 2,702 mm (20 mm increase since 7:00 on March 30)
	Water level of Reactor Building	O.P.+ 4,026 mm (72 mm increase since 7:00 on March 30)	O.P.+ 3,218 mm (27 mm decrease since 7:00 on March 30)	O.P.+ 2,856 mm (34 mm increase since 7:00 on March 30)	O.P.+ 2,750 mm (7 mm increase since 7:00 on March 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,222 mm (Increase from initial level:5,439 mm, 2 mm increase since 7:00 on March 30) O.P.+ 2,364 mm (Increase from initial level:3,090 mm, 19 mm increase since 7:00 on March 30) O.P.+ 4,411 mm (Water level from floor:615 mm, 6 mm increase since 7:00 on March 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:49 on March 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:11 on March 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.