

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 1)**

Water Level of the accumulated water (at 7:00 on April 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,999 mm (52 mm decrease since 7:00 on March 31)	O.P.+ 2,740 mm (18 mm increase since 7:00 on March 31)	—
	Water level of Turbine Building	O.P.+ 2,861 mm (23 mm increase since 7:00 on March 31)	O.P.+ 3,006 mm (44 mm decrease since 7:00 on March 31)	O.P.+ 2,784 mm (18 mm increase since 7:00 on March 31)	O.P.+ 2,722 mm (20 mm increase since 7:00 on March 31)
	Water level of Reactor Building	O.P.+ 4,024 mm (2 mm decrease since 7:00 on March 31)	O.P.+ 3,151 mm (67 mm decrease since 7:00 on March 31)	O.P.+ 2,881 mm (25 mm increase since 7:00 on March 31)	O.P.+ 2,754 mm (4 mm increase since 7:00 on March 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,226 mm (Increase from initial level:5,443 mm, 4 mm increase since 7:00 on March 31) O.P.+ 2,387 mm (Increase from initial level:3,113 mm, 23 mm increase since 7:00 on March 31) O.P.+ 4,421 mm (Water level from floor:625 mm, 10 mm increase since 7:00 on March 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:49 on March 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:11 on March 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.