

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 2)**

Water Level of the accumulated water (at 7:00 on April 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,944 mm (55 mm decrease since 7:00 on April 1)	O.P.+ 2,758 mm (18 mm increase since 7:00 on April 1)	—
	Water level of Turbine Building	O.P.+ 2,877 mm (16 mm increase since 7:00 on April 1)	O.P.+ 2,966 mm (40 mm decrease since 7:00 on April 1)	O.P.+ 2,802 mm (18 mm increase since 7:00 on April 1)	O.P.+ 2,739 mm (17 mm increase since 7:00 on April 1)
	Water level of Reactor Building	O.P.+ 4,000 mm (24 mm decrease since 7:00 on April 1)	O.P.+ 3,101 mm (50 mm decrease since 7:00 on April 1)	O.P.+ 2,898 mm (17 mm increase since 7:00 on April 1)	O.P.+ 2,761 mm (7 mm increase since 7:00 on April 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,228 mm (Increase from initial level:5,445 mm, 2 mm increase since 7:00 on April 1) O.P.+ 2,415 mm (Increase from initial level:3,141 mm, 28 mm increase since 7:00 on April 1) O.P.+ 4,428 mm (Water level from floor:632 mm, 7 mm increase since 7:00 on April 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:49 on March 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:11 on March 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.