

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 3)**

Water Level of the accumulated water (at 7:00 on April 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,916 mm (28 mm decrease since 7:00 on April 2)	O.P.+ 2,775 mm (17 mm increase since 7:00 on April 2)	—
	Water level of Turbine Building	O.P.+ 2,635 mm (242 mm decrease since 7:00 on April 2)	O.P.+ 2,934 mm (32 mm decrease since 7:00 on April 2)	O.P.+ 2,822 mm (20 mm increase since 7:00 on April 2)	O.P.+ 2,756 mm (17 mm increase since 7:00 on April 2)
	Water level of Reactor Building	O.P.+ 3,976 mm (24 mm decrease since 7:00 on April 2)	O.P.+ 3,076 mm (25 mm decrease since 7:00 on April 2)	O.P.+ 2,917 mm (19 mm increase since 7:00 on April 2)	O.P.+ 2,769 mm (8 mm increase since 7:00 on April 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,230 mm (Increase from initial level:5,447 mm, 2 mm increase since 7:00 on April 2) O.P.+ 2,569 mm (Increase from initial level:3,295 mm, 154 mm increase since 7:00 on April 2) O.P.+ 4,436 mm (Water level from floor:640 mm, 8 mm increase since 7:00 on April 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 9:50 on April 2 to 17:00 on April 2)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:49 on March 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:00 on April 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:18 AM on April 2, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 2:11 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 3:00 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.