

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 7)**

Water Level of the accumulated water (at 7:00 on April 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,920 mm (20 mm decrease since 7:00 on April 6)	O.P.+ 2,942 mm (17 mm increase since 7:00 on April 6)	—
	Water level of Turbine Building	O.P.+ 2,862 mm (45 mm increase since 7:00 on April 6)	O.P.+ 2,934 mm (19 mm decrease since 7:00 on April 6)	O.P.+ 2,987 mm (13 mm increase since 7:00 on April 6)	O.P.+ 2,881 mm (31 mm increase since 7:00 on April 6)
	Water level of Reactor Building	O.P.+ 4,407 mm (15 mm decrease since 7:00 on April 6)	O.P.+ 3,068 mm (21 mm decrease since 7:00 on April 6)	O.P.+ 3,094 mm (13 mm increase since 7:00 on April 6)	O.P.+ 2,859 mm (22 mm increase since 7:00 on April 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,300 mm (Increase from initial level:5,517 mm, 5 mm decrease since 7:00 on April 6) O.P.+ 2,326 mm (Increase from initial level:3,052 mm, 52 mm decrease since 7:00 on April 6) O.P.+ 4,372 mm (Water level from floor:576 mm, 47 mm increase since 7:00 on April 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:49 on March 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:00 on April 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.