

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 9)**

Water Level of the accumulated water (at 7:00 on April 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,858 mm (34 mm decrease since 7:00 on April 8)	O.P.+ 3,000 mm (15 mm increase since 7:00 on April 8)	—
	Water level of Turbine Building	O.P.+ 2,947 mm (42 mm increase since 7:00 on April 8)	O.P.+ 2,880 mm (28 mm decrease since 7:00 on April 8)	O.P.+ 3,040 mm (21 mm increase since 7:00 on April 8)	O.P.+ 2,936 mm (27 mm increase since 7:00 on April 8)
	Water level of Reactor Building	O.P.+ 4,323 mm (45 mm decrease since 7:00 on April 8)	O.P.+ 3,015 mm (32 mm decrease since 7:00 on April 8)	O.P.+ 3,149 mm (20 mm increase since 7:00 on April 8)	O.P.+ 2,900 mm (20 mm increase since 7:00 on April 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,191 mm (Increase from initial level:5,408 mm, 116 mm decrease since 7:00 on April 8) O.P.+ 2,244 mm (Increase from initial level:2,970 mm, 36 mm decrease since 7:00 on April 8) O.P.+ 4,456 mm (Water level from floor:660 mm, 40 mm increase since 7:00 on April 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:49 on March 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 8 to 15:00 on April 8)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:00 on April 2   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.