

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 15)**

Water Level of the accumulated water (at 7:00 on April 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,258 mm (71 mm increase since 7:00 on April 14)	O.P.+ 2,831 mm (33 mm decrease since 7:00 on April 14)	—
	Water level of Turbine Building	O.P.+ 2,852 mm (24 mm increase since 7:00 on April 14)	O.P.+ 3,218 mm (60 mm increase since 7:00 on April 14)	O.P.+ 2,803 mm (41 mm decrease since 7:00 on April 14)	O.P.+ 2,868 mm (28 mm decrease since 7:00 on April 14)
	Water level of Reactor Building	O.P.+ 4,154 mm (5 mm decrease since 7:00 on April 14)	O.P.+ 3,311 mm (62 mm increase since 7:00 on April 14)	O.P.+ 2,907 mm (39 mm decrease since 7:00 on April 14)	O.P.+ 2,913 mm (12 mm decrease since 7:00 on April 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,368 mm (Increase from initial level:5,585 mm, 5 mm increase since 7:00 on April 14) O.P.+ 2,297 mm (Increase from initial level:3,023 mm, 6 mm decrease since 7:00 on April 14) O.P.+ 4,418 mm (Water level from floor:622 mm, 5 mm increase since 7:00 on April 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:00 on April 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.