

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 16)**

Water Level of the accumulated water (at 7:00 on April 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,206 mm (52 mm decrease since 7:00 on April 15)	O.P.+ 2,834 mm (3 mm increase since 7:00 on April 15)	—
	Water level of Turbine Building	O.P.+ 2,879 mm (27 mm increase since 7:00 on April 15)	O.P.+ 3,174 mm (44 mm decrease since 7:00 on April 15)	O.P.+ 2,863 mm (60 mm increase since 7:00 on April 15)	O.P.+ 2,846 mm (22 mm decrease since 7:00 on April 15)
	Water level of Reactor Building	O.P.+ 4,153 mm (1 mm decrease since 7:00 on April 15)	O.P.+ 3,301 mm (10 mm decrease since 7:00 on April 15)	O.P.+ 2,957 mm (50 mm increase since 7:00 on April 15)	O.P.+ 2,900 mm (13 mm decrease since 7:00 on April 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,371 mm (Increase from initial level:5,588 mm, 3 mm increase since 7:00 on April 15) O.P.+ 2,319 mm (Increase from initial level:3,045 mm, 22 mm increase since 7:00 on April 15) O.P.+ 4,422 mm (Water level from floor:626 mm, 4 mm increase since 7:00 on April 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:09 on April 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:48 on March 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:00 on April 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.