

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 21)**

Water Level of the accumulated water (at 7:00 on April 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,043 mm (64 mm decrease since 7:00 on April 20)	O.P.+ 2,949 mm (18 mm increase since 7:00 on April 20)	—
	Water level of Turbine Building	O.P.+ 2,970 mm (13 mm increase since 7:00 on April 20)	O.P.+ 3,036 mm (51 mm decrease since 7:00 on April 20)	O.P.+ 2,993 mm (18 mm increase since 7:00 on April 20)	O.P.+ 2,919 mm (15 mm increase since 7:00 on April 20)
	Water level of Reactor Building	O.P.+ 4,087 mm (26 mm decrease since 7:00 on April 20)	O.P.+ 3,166 mm (44 mm decrease since 7:00 on April 20)	O.P.+ 3,103 mm (20 mm increase since 7:00 on April 20)	O.P.+ 2,915 mm (10 mm increase since 7:00 on April 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,389 mm (Increase from initial level:5,606 mm, 4 mm increase since 7:00 on April 20) O.P.+ 1,656 mm (Increase from initial level:2,382 mm, 77 mm decrease since 7:00 on April 20) O.P.+ 4,433 mm (Water level from floor:637 mm, 2 mm increase since 7:00 on April 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 16:39 on April 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:04 on April 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:04 on March 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on April 21 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:26 AM on April 21, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) to see the effect of water stop work at the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building).				

※ For quick publication of the data of water level, values are provided as reference values.