

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 23)**

Water Level of the accumulated water (at 7:00 on April 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,954 mm (44 mm decrease since 7:00 on April 22)	O.P.+ 2,970 mm (11 mm increase since 7:00 on April 22)	—
	Water level of Turbine Building	O.P.+ 2,998 mm (12 mm increase since 7:00 on April 22)	O.P.+ 2,957 mm (39 mm decrease since 7:00 on April 22)	O.P.+ 3,013 mm (11 mm increase since 7:00 on April 22)	O.P.+ 2,944 mm (11 mm increase since 7:00 on April 22)
	Water level of Reactor Building	O.P.+ 4,034 mm (29 mm decrease since 7:00 on April 22)	O.P.+ 3,095 mm (38 mm decrease since 7:00 on April 22)	O.P.+ 3,126 mm (9 mm increase since 7:00 on April 22)	O.P.+ 2,937 mm (10 mm increase since 7:00 on April 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,415 mm (Increase from initial level:5,632 mm, 14 mm increase since 7:00 on April 22) O.P.+ 1,731 mm (Increase from initial level:2,457 mm, 15 mm increase since 7:00 on April 22) O.P.+ 4,437 mm (Water level from floor:641 mm, 2 mm increase since 7:00 on April 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 16:39 on April 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:34 on April 21)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 22 to 15:00 on April 22)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on April 21 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on April 21 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.