

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 30)**

Water Level of the accumulated water (at 7:00 on April 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,072 mm (73 mm increase since 7:00 on April 29)	O.P.+ 2,815 mm (36 mm decrease since 7:00 on April 29)	—
	Water level of Turbine Building	O.P.+ 2,512 mm (7 mm increase since 7:00 on April 29)	O.P.+ 3,054 mm (62 mm increase since 7:00 on April 29)	O.P.+ 2,794 mm (39 mm decrease since 7:00 on April 29)	O.P.+ 2,862 mm (29 mm decrease since 7:00 on April 29)
	Water level of Reactor Building	O.P.+ 3,938 mm (18 mm increase since 7:00 on April 29)	O.P.+ 3,153 mm (61 mm increase since 7:00 on April 29)	O.P.+ 2,897 mm (42 mm decrease since 7:00 on April 29)	O.P.+ 2,977 mm (14 mm decrease since 7:00 on April 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,217 mm (Increase from initial level:5,434 mm, 7 mm increase since 7:00 on April 29) O.P.+ 2,066 mm (Increase from initial level:2,792 mm, 77 mm decrease since 7:00 on April 29) O.P.+ 4,201 mm (Water level from floor:405 mm, 2 mm increase since 7:00 on April 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:35 on April 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.