

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 1)**

Water Level of the accumulated water (at 7:00 on May 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,145 mm (73 mm increase since 7:00 on April 30)	O.P.+ 2,780 mm (35 mm decrease since 7:00 on April 30)	—
	Water level of Turbine Building	O.P.+ 2,517 mm (5 mm increase since 7:00 on April 30)	O.P.+ 3,116 mm (62 mm increase since 7:00 on April 30)	O.P.+ 2,761 mm (33 mm decrease since 7:00 on April 30)	O.P.+ 2,835 mm (27 mm decrease since 7:00 on April 30)
	Water level of Reactor Building	O.P.+ 3,982 mm (44 mm increase since 7:00 on April 30)	O.P.+ 3,223 mm (70 mm increase since 7:00 on April 30)	O.P.+ 2,862 mm (35 mm decrease since 7:00 on April 30)	O.P.+ 2,958 mm (19 mm decrease since 7:00 on April 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,221 mm (Increase from initial level:5,438 mm, 4 mm increase since 7:00 on April 30) O.P.+ 1,999 mm (Increase from initial level:2,725 mm, 67 mm decrease since 7:00 on April 30) O.P.+ 4,203 mm (Water level from floor:407 mm, 2 mm increase since 7:00 on April 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 30 to 15:00 on April 30)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:35 on April 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.