

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 2)**

Water Level of the accumulated water (at 7:00 on May 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,129 mm (16 mm decrease since 7:00 on May 1)	O.P.+ 2,804 mm (24 mm increase since 7:00 on May 1)	—
	Water level of Turbine Building	O.P.+ 2,558 mm (41 mm increase since 7:00 on May 1)	O.P.+ 3,100 mm (16 mm decrease since 7:00 on May 1)	O.P.+ 2,845 mm (84 mm increase since 7:00 on May 1)	O.P.+ 2,817 mm (18 mm decrease since 7:00 on May 1)
	Water level of Reactor Building	O.P.+ 4,204 mm (222 mm increase since 7:00 on May 1)	O.P.+ 3,244 mm (21 mm increase since 7:00 on May 1)	O.P.+ 2,940 mm (78 mm increase since 7:00 on May 1)	O.P.+ 2,945 mm (13 mm decrease since 7:00 on May 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,227 mm (Increase from initial level:5,444 mm, 6 mm increase since 7:00 on May 1) O.P.+ 2,094 mm (Increase from initial level:2,820 mm, 95 mm increase since 7:00 on May 1) O.P.+ 4,213 mm (Water level from floor:417 mm, 10 mm increase since 7:00 on May 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on May 1 to 15:00 on May 1)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:52 on May 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:04 AM on May 1, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 1:14 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 1:52 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.